




IHRE EXPERTEN FÜR KUGELHÄHNE UND SICHERHEITSARMATUREN  
YOUR EXPERTS FOR BALL VALVES AND SAFETY VALVES



## BEDIENUNGS- UND MONTAGEANLEITUNG



**998NG - TAS MOP 5 C1**



## 1. Anwendungsbereich

### Hinweis

Die Armatur mit Selbstauslösender thermischer Armaturensicherung ( TAS ) muss gemäß der Anwendung mit CE-Ident. Nr., nach den Vorschriften der EN 331 und DIN 3586 gekennzeichnet sein.

### 1.1 Installationsbereich Gase nach G260/1

EN 331 DIN3586 MOP5 C1 Temperaturklasse -20°C bis +60  
DVGW-Reg. Nr. NG-4341BR0017

### 1.2 Absperrarmatur gem. der Gasgeräteverordnung EU/2016/426

CE-Ident.-Nr. CE-0085BR0016

## 2. Einbau / Montage

Die Kugelhahn TAS Kombination wird grundsätzlich in Offenstellung geliefert. Der Einbau soll in der Regel auch in Offenstellung erfolgen. Die Durchflussrichtung ist zu beachten. Die Montage muß fachgerecht nach Anforderungen der gültigen Installationsrichtlinien (z.B. TRGI) durchgeführt werden. Armaturen mit ausgelöster TAS dürfen nicht montiert werden. Zur Abdichtung der Gewindeverbindung müssen geeignete Dichtmittel verwendet werden. (Dichtmittel nach DIN 30660) Armaturen sollen nicht den Spannungen des Leitungssystems ausgesetzt sein, da ansonsten die Funktion negativ beeinträchtigt werden kann. Nach dem Einbau ist ein Reinigungsvorgang des Leitungssystems erforderlich, um Installationsrückstände zu entfernen und eine eventuelle Beschädigung der integrierten TAS als auch der Kugeldichtung zu verhindern. Farbanstriche, Isolierungen, Schutzverkleidungen usw. sind unzulässig.

## 3. Bedienung

Schließen: 90° Drehung des Bedienungshebels im Uhrzeigersinn.  
Öffnen: 90° Drehung des Bedienungshebels gegen den Uhrzeigersinn.  
Die Stellung der Schaltspindel zeigt die Kugelstellung - Offen / Geschlossen an. Die Armatur darf nur in Offen- oder Geschlossenstellung betrieben werden. Zwischenstellungen ( Regelfunktion ) beschädigen die Kugeldichtung. Dies kann zur Undichtheit in Absperrfunktion führen.  
Die Armatur ist vor Umgebungstemperaturen über 60°C ( z.B. Sonneneinstrahlung ) zu schützen, da die integrierte thermische Armaturensicherung auslösen kann und somit den Durchfluss verschließt. ( Auslösetemperatur 95°C +/- 5° )

## 4. Wartung

Bee Kugelhähne sind wartungsfrei.

## 5. Warnhinweise

Bei Zerstörung oder Verschleiß eines Kugelhahnteiles, muß die komplette Armatur getauscht werden. Bauliche Änderungen an Armaturen sind unzulässig. Die Durchflußmenge muß auf den vorgesehenen Bestimmungszweck abgestimmt sein. Die Installation muß in Übereinstimmung der örtlichen Installationsbedingungen erfolgen. Die Installationsanweisungen des Herstellers sind zu beachten. Bei unsachgemäßer Montage oder/und Bedienung erlischt jeglicher Gewährleistungsanspruch. Im Reparaturfall darf die Kugelhahn TAS Kombination nur im Herstellerwerk geöffnet werden.

## Konformitätserklärung

Dieses Produkt wurde gemäß den technischen Richtlinien und DIN-EN Normen hergestellt. Das zur Herstellung verwendete Messing besteht ausschließlich aus Legierungen nach DIN EN 12420 und erfüllt die Vorschriften des DVGW Regelwerkes. Wir erklären die Konformität mit den angewandten Regelwerken und bescheinigen, daß BEE – Kugelhähne mit integrierter TAS dem baumustergeprüften Produkt entsprechen.

## Field of application

### Note

The valve with automatic thermal release (TAS) must be marked according to the standards EN 331 and DIN 3586 with CE Identification No. or National Registration No..

### 1.1 Installation fields of gases in accordance with G260/1

EN 331 DIN3586 MOP5 C1 temperature range from -20°C to +60°C  
DVGW Reg. No. NG-4341BR0017.

### 1.2 Shut-off valves in accordance with the Gas Appliance Regulation EC/2016/426

CE Identification No. CE-0085BR0016.

## 2. Installation / Assembly

The ball valve TAS combination is always supplied in the open position. In general, they are to be installed in the open position. The direction of flow must be adhered to. The ball valve must be assembled professionally in accordance with the present installation regulations (f.ex. TRGI ). Valves with a tripped TAS must not be assembled. Appropriate agents must be used to seal the threaded joint (sealing agents in conformity with DIN 30660) Valves are not subject to the stresses of the pipe system, as their function may otherwise be impaired. After installation, the pipe system must be flushed out in order to remove any residual matter and to prevent possible damage to the integrated TAS and the ball seal. Coats of paint, insulations and protective clothing etc., are not allowed.

## 3. Operation

To close: Turn the operating lever 90° clockwise.  
To open: Turn the operating lever 90° anti-clockwise.  
The position of the spindle indicates the ball position - Open / Closed.  
The valve may only be operated in the Open or Closed position. Intermediate positions (control function) can damage the ball seal. This can cause leakage in the shut-off function.  
The valve must be protected from ambient temperatures above 60°C (e.g., sun rays), since this may trigger the thermal release and thus shut off the flow. (Triggering temperature 95°C +/- 5°)

## 4. Maintenance

BEE ball valves series 834 are maintenance free.

## 6. Warnings

In case of destruction or wear of a ball valve part, the complete valve must be replaced. Structural changes to valves are not permitted.  
The flow rate must be matched to the intended purpose.  
Installation must be in accordance with local installation conditions.  
The installation instructions of the manufacturer are to be observed.  
Incorrect assembly and/or operation will invalidate the right to make claims under the warranty. In the event of repair the ball valve TAS combination may only be opened in the manufacturer's plant.

## 7. Miscellaneous

Incorrect assembly and/or operation will invalidate the right to make claims under the warranty. In the event of repair, the ball valve may only be opened in the manufacturer's plant. In case of emptying the tube system, ball valves are also to be taken into consideration. (danger of freezing) The safety indications on the declaration of conformity must be adhered to.

## 8. Declaration of the manufacturer

This product has been manufactured in accordance with the technical guidelines and DIN-EN standards. The brass materials used to manufacture our products comply with the regulations according to DIN EN 12420. We hereby declare that the valves with integrated TAS conform to the applicable DVGW regulations and confirm that BEE ball valves correspond to the design type-tested product.

**BEDIENUNGS- UND MONTAGEANLEITUNG FÜR BEE- ARMATUREN DER BAUREIHE 998NG - TAS MOP 5 C1**  
**OPERATING AND ASSEMBLY INSTRUCTIONS FOR BEE VALVES SERIES 998NG - TAS MOP 5 C1****Konformitätserklärung**

gemäß Anhang 4 der Druckgeräterichtlinie 2014/68/EU und Anhang 3 der GAR EU/2016/426

Hersteller G. Bee GmbH  
Robert-Bosch-Straße 14  
D-71691 Freiberg a. N.**Beschreibung**

Kugelhahn mit eingangsseitig integrierter thermischer Armaturensicherung „TAS“, zur Absperrung und thermischer Absicherung nach geschalteter Objekte in der Gasinstallation. (Druck haltendes Ausrüstungsteil).

**Angewandte Konformitätsbewertungsverfahren**

PED: Modul H ( Umfassende Qualitätssicherung ) benannte Stelle TÜV Rheinland (CE-0035) GAR: EU/ 2016/426 Baumusterprüfung benannte Stelle DVGW (CE-0085)

**Angewandte Regelwerke**

Einteilung	Regelwerke
Auslegung	AD2000 – A4, DIN 3840
Gewindeanschluss	ISO 7-1, DIN EN 10226-1
Anwendungsbedingte Regelwerke	DIN-EN-331-2016, DIN3586, PED 2014/68/EC, GAR EU/2016/426
Prüfungen	DIN3230-5, DIN EN 12266-1
Elastomere	DIN EN 549, DIN EN 682
Kennzeichnung	DIN EN 19, PED 2014/68/EU, GAR EU/2016/426, DIN EN331, DIN 3586

Wir erklären, daß das Produkt mit der Richtlinie 2014/68/EU und EU/2016/426 übereinstimmt und oben genannten Konformitätsbewertungsverfahren unterzogen wurde.

**Risikoanalyse**

Der Kugelhahn mit eingangsseitig integrierter TAS ist auf Belastungen ausgelegt, die der beabsichtigten Verwendung und anderen nach vernünftigem Ermessen vorhersehbaren Betriebsbedingungen angemessen ist. Insbesondere sind folgende Faktoren zu berücksichtigen.

**Druckbelastung**

Die Druckbelastung muß in dem angegebenen Druckbereich liegen. Gegen eine Drucküberschreitung sowie Druckschläge sind geeignete Maßnahmen zu ergreifen. Zu Prüfzwecken kann die Armatur mit 1.5xNennndruck beaufschlagt werden.

**Temperaturbelastung**

Die Umgebungstemperatur darf 60°C nicht überschreiten, da ansonsten die thermische Armaturensicherung auslöst und den Durchfluß absperrt. Auslösetemperatur 95°±5° Ausgelöste TAS müssen erneuert werden.

**Beständigkeit gegenüber dem Medium**

Alle Werkstoffe sind auf dem Datenblatt aufgeführt. Die chemische Verträglichkeit muß sichergestellt sein.

**Reaktionskräfte**

Reaktionskräfte und –Momente im Zusammenhang mit Tragelementen, Rohrleitungen Befestigungen usw. dürfen die in EN331 aufgeführten Momente nicht überschreiten.

**Durch Auslegung und Bau muss folgendes sichergestellt sein**

Der Gefahr einer Überbeanspruchung durch unzulässige Bewegung oder übermäßige Kräfte z.B. an Armaturen ist durch Unterstützung, Befestigung, Ausrichtung in geeigneter Weise vorzubeugen. Bei gasförmigen Fluiden die Kondensflüssigkeiten bilden sind geeignete Einrichtungen zur Entwässerung zur Vermeidung von Schäden durch Wasserschlag und Korrosion vorzusehen. Die Gefahr von Ermüdungserscheinungen durch Vibration des Rohrleitungssystems sind gebührend zu berücksichtigen.

Freiberg a.N. 25.01.2018

Michael Boger Konstruktion / Entwicklung design / development

Unterschrift Signature

**Declaration of the conformity**

in accordance with Appendix 4 of the Pressure Equipment Directive 2014/68/EC and GAR EC/2016/426

Manufacturer: G. Bee GmbH  
Robert-Bosch-Straße 14  
D-71691 Freiberg a. N.**Description**

Ball valve with integrated „TAS“ thermal release on the supply side for shut-off and thermal protection of objects connected on the load side in the gas installation. (pressure-maintaining plant component ).

**Applicable conformity evaluation procedure**

PED: Module H (Quality Assurance) notified body TÜV Rheinland (CE-0035) GAR EC/2016/426: Type approval notified body DVGW (CE-0085)

**Applicable rules**

Classification	Regulations
Construction	AD2000 – A4, DIN 3840
Thread Connection	ISO 7-1, DIN EN 10226-1
Application-specific regulations	DIN-EN-331-2016 DIN3586, PED 2014/68/EC, GAR EC/2016/426
Tests	DIN3230-5, DIN EN 12266-1
Elastomers	DIN EN 549, DIN EN 682
Marking	DIN EN 19, PED 2014/68/EU, GAR EC/2016/426, DIN EN331, DIN 3586

We hereby declare that the product conforms to Directive 2014/68/EC and GAR EC/2016/426 and has undergone the above-mentioned conformity evaluation procedure.

**Risk analysis**

Ball valves with integrated TAS on the supply side are designed for loads which are appropriate to the intended use and other foreseeable operating conditions that are considered to be reasonable. The following factors in particular must be taken into consideration.

**Pressure load**

The pressure load must not exceed the pressure range specified. Appropriate measures must be taken to avoid excess pressure or pressure impacts. For the purpose of testing the valve can be impacted with 1.5x nominal pressure.

**Temperature stress**

The ambient temperature may not exceed 60°C, since otherwise the thermal release is tripped and shuts off the flow. Tripping temperature 95±5° Once tripped, TAS's must be replaced.

**Resistance to the medium**

All the materials are listed on the data sheet. Their chemical compatibility must be guaranteed.

**Reaction Forces**

Reaction forces and moments in connection with supporting elements, pipeline fixings, etc., may not exceed the moments specified in EN331.

**Design and construction must guarantee the following**

Appropriate methods of support, fixing and alignment must be used to prevent the risk of overstressing by e.g., inadmissible movement or excessive force on valves. In the case of gaseous fluids that form condensate, suitable dehydration facilities must be provided to prevent damage caused by water shock and corrosion. The risk of fatigue phenomena caused by vibration of the pipeline system must be given due consideration.



KUGELHÄHNE | Manueller Betrieb BALL VALVES | manually operated

## BEDIENUNGS- UND MONTAGEANLEITUNG FÜR BEE- ARMATUREN DER BAUREIHE 998NG - TAS MOP 5 C1 OPERATING AND ASSEMBLY INSTRUCTIONS FOR BEE VALVES SERIES 998NG - TAS MOP 5 C1

### Zulassungen Approvals



Einstufung nach PED 2014-68-EU Kategorie 0  
Classification acc. to PED 2014-68-EU category 0



DVGW Zulassung nach Gasgeräteverordnung GAR EU-2016-426  
DVGW-approval acc. to gas appliance regulation GAR EU-2016-426



DVGW Gas Zulassung MOP5 nach DIN EN 331 und  
DIN 3586 C1 GT1

DVGW gas approval MOP5 acc. to DIN EN 331 and  
DIN 3586 C1 GT1



Zulassung Gas thermisch bis 650°C belastbar  
DVGW gas approval thermally resistant up to 650°C



**G. Bee GmbH**  
Kugelhähne und Sicherheitsarmaturen  
Ball Valves and Safety Valves  
Robert-Bosch-Straße 14  
71691 Freiberg am Neckar | Germany

T +49 7141 9744-0  
F +49 7141 9744-155  
sales@g-bee.de  
www.g-bee.de

